TABLE OF DETECTED CONTAMINANTS							
Contaminant	**Violation Y/N**	**Date of Sample**	**Level Detected**	**Unit Measurement**	**MCLG**	**MCL**	**Likely Source of Contamination**
Radiological Contaminants							
Gross Beta Well #1 (Footnote #1)	N	5/3/04	3.2	pCi/l	0	50	Decay of natural deposits and man-made emissions.
Gross Beta Well #2 (Footnote #1)	N	5/3/04	2.3	pCi/l	0	50	Decay of natural deposits and man-made emissions.
Radium 224 Well #2	N	5/3/04	2.4	pCi/l	0	50	Decay of natural deposits.
Inorganic Compounds							
Fluoride	N	Monthly	0.93 Average (0.8-1.0 Range)	ppm	N/A	2.2	Erosion of natural deposits; Water additive that promotes stong teeth; Discharge from fertilizer and aluminum plants.
Sodium Well #1 (Footnote #2)	N	9/12/08	68	ppm	N/A	N/A	Naturally occurring; Road Salt: Water Softeners; Animal Wastes.
Sodium Well #2 (Footnote #2)	N	9/12/08	63	ppm	N/A	N/A	Naturally occurring; Road Salt: Water Softeners; Animal Wastes.
Barium Well #1	N	6/19/07	91	ppb	2000	2000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Barium Well #2	N	6/19/07	110	ppb	2000	2000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Nitrate Well #1	N	8/20/08	2.1	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate Well #2	N	8/20/08	2.2	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Lead (Footnote #3)	N	8/29-9/2/2008	7.6 (Range: 2.0-15)	ppb	0	AL=15	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper (Footnote #4)	N	8/29-9/2/2008	220 (Range: 4.9-500)	ppb	1300	AL=1300	Corrosion of household plumbing systems; Erosion of natural deposits. Leaching of wood preservatives.
Disinfection By-Products							
Total Trihalomethanes	N	8/14/07	14	ppb	N/A	80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
Non-Regulated Contaminants							
Nickel Well #1	N	2/11/04	3.4	ppb	0.1	N/A	Naturally occurring; Product of industrial coal gasification, smelting, refining, steelworking.
Nickel Well #2	N	2/11/04	3.4	ppb	0.1	N/A	Naturally occurring; Product of industrial coal gasification, smelting, refining, steelworking.
Magnesium Well #1	N	9/12/08	0.14	ppm	N/A	N/A	Naturally occurring.
Magnesium Well #2	N	7/1/03	24	ppm	N/A	N/A	Naturally occurring.
Calcium Well #1	N	9/12/08	92	ppm	N/A	N/A	Naturally occurring.
Calcium Well #2	N	7/1/03	100	ppm	N/A	N/A	Naturally occurring.
Total Hardness as CaCO3 Well #1	N	10/15/08	320	ppm	N/A	N/A	Naturally occurring.
Total Hardness as CaCO3 Well #2	N	7/1/03	350	ppm	N/A	N/A	Naturally occurring.
Sulfate Well #1	N	7/1/03	27	ppm	N/A	250	Naturally occurring.
Sulfate Well #2	N	7/1/03	26	ppm	N/A	250	Naturally occurring.
Chloride Well #1	N	7/1/03	108	ppm	N/A	250	Naturally occurring; indicative of road salt contamination
Chloride Well #2	N	7/1/03	95	ppm	N/A	250	Naturally occurring; indicative of road salt contamination